

Approval Number: 2008533
Test Report: J-00364892



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

15th October 2020

Gulf Plastic and Converting Industries RAKtherm
Al Jazeerah al hammrah,
Ras Al khimah,
P.O.BOX 30739,
United Arab Emirates

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE - COMPONENTS.

5260

'RAKtherm PPR Pipe'. Green coloured, extruded PPR pipe. For use with water up to 65°C.

APPROVAL NUMBER: 2008533

APPROVAL HOLDER: GULF PLASTIC AND CONVERTING INDUSTRIES RAKTHERM

The Scheme reserves the right to review approval.

Approval 2008533 is valid between August 2020 and August 2025

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme

Approval Number: 2008534
Test Report: J-00364892 & J-00364893



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

15th October 2020

Gulf Plastic and Converting Industries RAKtherm
Al Jazeerah al hammrah,
Ras Al khimah,
P.O.BOX 30739,
United Arab Emirates

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE - COMPONENTS.

5260

'RAKtherm PPR Fittings'. Green coloured, injection moulded PPR fittings. For use with water up to 65°C.

APPROVAL NUMBER: 2008534

APPROVAL HOLDER: GULF PLASTIC AND CONVERTING INDUSTRIES RAKTHERM

The Scheme reserves the right to review approval.

Approval 2008534 is valid between August 2020 and August 2025

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme